



160008113188



中国认可  
国际互认  
检测  
TESTING  
CNAS L0942

# SPECIAL EQUIPMENT TYPE-TEST CERTIFICATE ( Elevator )

Certificate No. TSX F31003720180073

**Applicant Name:** Guangdong Huahui Elevator Accessories Co., Ltd.

**Applicant address:** West of Gangkou Road, Dongqu Sanshan, Guicheng Street, Nanhai District, Foshan City, Guangdong Province, P.R. China

**Manufacturer name:** Guangdong Huahui Elevator Accessories Co., Ltd.

**Manufacturer address:** West of Gangkou Road, Dongqu Sanshan, Guicheng Street, Nanhai District, Foshan City, Guangdong Province, P.R. China

**Equipment type:** Lift Safety Protection Device      **Equipment kind:** Overspeed governor

**Product name:** Overspeed governor      **Product type:** XSG607-B15

Inspection report No. TSX F310T3720180073 TSX F310T3720200044H

By the Type-Test, the prototype (product) is confirmed to be in accordance with Regulation for Type Tests of Elevators ( TSG T7007-2016 ), GB 7588-2003 Safety Rules for the Construction and Installation of Electric Lifts ( Including 1<sup>st</sup> Revision List ) and EN 81-1:1998+A3:2009.

Applicable product type of the certificate: XSG607-B15

Applicable product parameter range and configuration is to see the annex.

Issue date: 2018/07/07 (Stamp)

Date of replacement: 2020/05/08

Date of next inspection: Before 2022/07/07

**Guangdong Institute of Special Equipments Inspection and Research  
National Elevator Quality Supervision and Inspection Center  
( Guangdong )**

- Note 1:** Applicant has the responsibility to ensure that products comply with the provisions of the safety technical norms and standards, and the consistency with experimental testing prototype (sample).
- Note 2:** This certificate shall not apply to the products manufactured after the next check date.
- Note 3:** The elevator standards involved in this certificate has been accepted by CNAS laboratory, and TSG T7007-2016 is temporarily not within the scope of CNAS accept recognition.

**Product Technical Parameters and Configuration Table**

<b>Rated Speed</b>		1.5m/s	<b>Structure Pattern</b>	Centrifuge block type
<b>Structure for tension force generation</b>		Clamping type	<b>Rope Sheave Pitch Circle Diameter</b>	240mm
<b>Wire rope Diameter</b>		8mm	<b>Rope Race Type</b>	U groove
<b>Rope Tension Force</b>		/N	<b>Pulling Force</b>	850 ~ 1950 N
<b>Mechanical Triggering Device</b>	<b>Active safety gear of car or counterweight downwards.</b>			Configured
	<b>Active wire rope brake</b>			Not Configured
	<b>Active safety gears of car upwards</b>			Not Configured
	<b>Active other type of brake unit for ACOP</b>			Not Configured
<b>Electric Security Protector &amp; Electric Tripping Device</b>	<b>Electric device on overspeed checking</b>			Configured
	<b>Electric device on reset checking</b>			Configured
	<b>Active device of ACOP</b>	<b>Active brakes on drive machine</b>		Configured
		<b>Active brake unit on wire rope or traction sheave</b>		Not Configured
<b>Active brake unit of other type</b>		Not Configured		
<b>Remote control function</b>		Not Configured	<b>Working condition</b>	Indoors
<b>Explosion-proof type</b>		Not applicable		